

| MEDICAL GAS OUTLETS FOR AIIMS BHUBANESHWAR | | | | | | | | | | | |
|--|--------------|---------------------------------------|-----------|---------------|--------|-----------|-----------|------------------|------|----------------------------------|------------------|
| BLOCK | FLOOR | DESCRIPTION OF ROOM | ROOM NO | NO OF OUTLETS | | | | | | SINGLE ARM MOVABLE PENDANT | BEDHEAD PANEL |
| | | | | OXYGEN | VACUUM | AIR 4 BAR | AIR 7 BAR | NITROUS OXIDE | AGSS | | |
| HOSPITAL | LOWER GROUND | LOW TEMPERATURE STERILIZATION ZONE | HB 1007 F | 0 | 0 | 2 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | LOWER GROUND | SIMULATOR ROOM | HB 1018 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | LOWER GROUND | LINAC - LOW ENERGY | HB 1021 | 1 | 1 | 1 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | LOWER GROUND | LINAC - HIGH ENERGY | HB 1022 | 1 | 1 | 1 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | LOWER GROUND | RECOVERY ROOM(2 BED) | HB 1029 | 4 | 4 | 2 | 0 | 0 | 0 | 0 | 2 |
| HOSPITAL | LOWER GROUND | MINOR OT | HB 1031 | 2 | 2 | 2 | 0 | 1 | 1 | 1 | 0 |
| HOSPITAL | LOWER GROUND | PROCEDURE 1 | HB 1053 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | LOWER GROUND | PROCEDURE 2 | HB 1059 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | LOWER GROUND | PROCEDURE 3 | HB 1060 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | LOWER GROUND | PROCEDURE | HB 1079 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | LOWER GROUND | PROCEDURE | HB 1084 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | LOWER GROUND | PROCEDURE | HB 1085 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | LOWER GROUND | PROCEDURE | HB 1119 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | LOWER GROUND | PROCEDURE | HB 1120 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | LOWER GROUND | PROCEDURE | HB 1125 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | SPL PROCEDURE ROOM 2 | HB 2207 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | SPL PROCEDURE ROOM 1 | HB 2212 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | CT SCAN | HB 2229 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | WARD 11 BED | HB 2245 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | ISOLATION ROOM | HB 2257 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | GROUND | WARD 13 BED | HB 2266 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | ISOLATION ROOM | HB 2269 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | GROUND | TRAUMA 2 10 BED | HB 2281 | 6 | 6 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | ISOLATION ROOM | HB 2284 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | GROUND | ISOLATION ROOM | HB 2285 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | GROUND | ISOLATION ROOM | HB 2288 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | GROUND | ISOLATION ROOM | HB 2289 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | GROUND | TRAUMA 1 10 BED | HB 2290 | 6 | 6 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | RESUSITATION AREA 4 BED | HB 2297 | 8 | 8 | 4 | 0 | 0 | 0 | 0 | 4 |
| HOSPITAL | GROUND | TRAUMA 3 TRIAGE 10 BED | HB 2316 | 6 | 6 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | ISOLATION ROOM | HB 2317 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | GROUND | ISOLATION ROOM | HB 2318 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2332 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2333 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2334 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2335 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |

| MEDICAL GAS OUTLETS FOR AIIMS BHUBANESHWAR | | | | | | | | | | | |
|--|--------|---|---------|---------------|--------|-----------|-----------|------------------|------|----------------------------------|------------------|
| BLOCK | FLOOR | DESCRIPTION OF ROOM | ROOM NO | NO OF OUTLETS | | | | | | SINGLE ARM MOVABLE PENDANT | BEDHEAD PANEL |
| | | | | OXYGEN | VACUUM | AIR 4 BAR | AIR 7 BAR | NITROUS OXIDE | AGSS | | |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2336 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2337 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2338 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2339 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2340 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2341 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2347 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2348 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2349 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2357 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2358 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2359 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | MRI | HB 2401 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | CT SCAN | HB 2405 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2407 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2408 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2409 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2410 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2411 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2412 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2413 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2414 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2415 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2416 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2426 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2427 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2428 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2438 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2439 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2440 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | INFECTIOUS BED(2 BED) | HB 2471 | 4 | 4 | 2 | 0 | 0 | 0 | 0 | 2 |
| HOSPITAL | GROUND | DIALYSIS / BLOOD BANK- NON INFECTIOUS BED(4 BED) | HB 2480 | 8 | 8 | 4 | 0 | 0 | 0 | 0 | 4 |
| HOSPITAL | GROUND | MINOR OT | HB 2482 | 2 | 2 | 2 | 0 | 1 | 1 | 1 | 0 |
| HOSPITAL | GROUND | SPECIAL PROCEDURE ROOM | HB 2489 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2500 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2501 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |

| MEDICAL GAS OUTLETS FOR AIIMS BHUBANESHWAR | | | | | | | | | | | |
|--|--------|------------------------------|---------|---------------|--------|-----------|-----------|------------------|------|----------------------------------|------------------|
| BLOCK | FLOOR | DESCRIPTION OF ROOM | ROOM NO | NO OF OUTLETS | | | | | | SINGLE ARM MOVABLE PENDANT | BEDHEAD PANEL |
| | | | | OXYGEN | VACUUM | AIR 4 BAR | AIR 7 BAR | NITROUS OXIDE | AGSS | | |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2502 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2512 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2513 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2514 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2519 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2520 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2521 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2522 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2523 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2524 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2525 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2526 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2527 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | GROUND | PRIVATE ROOM | HB 2528 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIRST | WARD (13 BED) | HB 3189 | 7 | 7 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIRST | WARD (13 BED) | HB 3193 | 7 | 7 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIRST | ISOLATION ROOM | HB 3198 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FIRST | ISOLATION ROOM | HB 3210 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FIRST | POST OPERATIVE WARD 4 BED | HB 3216 | 4 | 4 | 2 | 0 | 0 | 0 | 0 | 2 |
| HOSPITAL | FIRST | PRE OPERATIVE WARD 6 BED | HB 3218 | 4 | 4 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIRST | WARD (13 BED) | HB 3261 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIRST | WARD (13 BED) | HB 3266 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIRST | ISOLATION ROOM | HB 3269 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FIRST | ISOLATION ROOM | HB 3281 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FIRST | WARD (4 BED) | HB 3292 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIRST | WARD (4 BED) HDU | HB 3293 | 8 | 8 | 4 | 0 | 0 | 0 | 0 | 4 |
| HOSPITAL | FIRST | WARD (4 BED) | HB 3294 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIRST | WARD (4 BED) | HB 3302 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIRST | WARD (4 BED) | HB 3303 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIRST | ISOLATION ROOM | HB 3309 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FIRST | ISOLATION ICU(7 BED) | HB 3312 | 14 | 14 | 7 | 0 | 0 | 0 | 0 | 7 |
| HOSPITAL | FIRST | ISOLATION ICU(7 BED) | HB 3319 | 14 | 14 | 7 | 0 | 0 | 0 | 0 | 7 |
| HOSPITAL | FIRST | ISOLATION ICU(7 BED) | HB 3322 | 14 | 14 | 7 | 0 | 0 | 0 | 0 | 7 |
| HOSPITAL | FIRST | ISOLATION ICU(7 BED) | HB 3329 | 14 | 14 | 7 | 0 | 0 | 0 | 0 | 7 |
| HOSPITAL | FIRST | WARD (4 BED) | HB 3351 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIRST | WARD (4 BED) HDU | HB 3352 | 8 | 8 | 4 | 0 | 0 | 0 | 0 | 4 |
| HOSPITAL | FIRST | WARD (4 BED) | HB 3353 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |

| MEDICAL GAS OUTLETS FOR AIIMS BHUBANESHWAR | | | | | | | | | | | |
|--|--------------|---------------------------|---------|---------------|--------|-----------|-----------|------------------|------|----------------------------------|------------------|
| BLOCK | FLOOR | DESCRIPTION OF ROOM | ROOM NO | NO OF OUTLETS | | | | | | SINGLE ARM MOVABLE PENDANT | BEDHEAD PANEL |
| | | | | OXYGEN | VACUUM | AIR 4 BAR | AIR 7 BAR | NITROUS OXIDE | AGSS | | |
| HOSPITAL | FIRST | WARD (4 BED) | HB 3361 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIRST | WARD (4 BED) | HB 3362 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIRST | ISOLATION ROOM | HB 3367 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FIRST | ISOLATION ROOM | HB 3383 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FIRST | WARD (4 BED) | HB 3388 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIRST | WARD (4 BED) | HB 3389 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIRST | WARD (4 BED) | HB 3396 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIRST | WARD (4 BED) HDU | HB 3397 | 8 | 8 | 4 | 0 | 0 | 0 | 0 | 4 |
| HOSPITAL | FIRST | WARD (4 BED) | HB 3398 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIRST | PRE OPERATIVE WARD 4 BED | HB 3403 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIRST | POST OPERATIVE WARD 6 BED | HB 3437 | 12 | 12 | 6 | 0 | 0 | 0 | 0 | 6 |
| HOSPITAL | SECOND FLOOR | WARD 14 BED | HB 4137 | 9 | 9 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | WARD 14 BED | HB 4149 | 9 | 9 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | ISOLATION ROOM | HB 4150 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | SECOND FLOOR | ISOLATION ROOM | HB 4160 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | SECOND FLOOR | WARD (13 BED) | HB 4169 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | WARD (13 BED) | HB 4174 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | ISOLATION ROOM | HB 4179 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | SECOND FLOOR | ISOLATION ROOM | HB 4191 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | SECOND FLOOR | NURSERY | HB 4196 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | DELIVERY | HB 4203 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | POSTNATAL(2 BED) | HB 4209 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | ECL.DELIVERY ROOM(2 BED) | HB 4218 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | SEPTIC NURSERY | HB 4222 | 4 | 4 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | SEPTIC DELIVERY(4 BED) | HB 4223 | 4 | 4 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | PRENATAL | HB 4225 | 1 | 1 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | WARD (13 BED) | HB 4238 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | WARD (13 BED) | HB 4243 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | ISOLATION ROOM | HB 4246 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | SECOND FLOOR | ISOLATION ROOM | HB 4258 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | SECOND FLOOR | ISOLATION ICU(7 BED) | HB 4263 | 14 | 14 | 7 | 0 | 0 | 0 | 0 | 7 |
| HOSPITAL | SECOND FLOOR | ISOLATION ICU(7 BED) | HB 4270 | 14 | 14 | 7 | 0 | 0 | 0 | 0 | 7 |
| HOSPITAL | SECOND FLOOR | ISOLATION ICU(7 BED) | HB 4273 | 14 | 14 | 7 | 0 | 0 | 0 | 0 | 7 |
| HOSPITAL | SECOND FLOOR | ISOLATION ICU(7 BED) | HB 4280 | 14 | 14 | 7 | 0 | 0 | 0 | 0 | 7 |
| HOSPITAL | SECOND FLOOR | WARD (4 BED) | HB 4301 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | HDU (4 BED) | HB 4302 | 8 | 8 | 4 | 0 | 0 | 0 | 0 | 4 |

| MEDICAL GAS OUTLETS FOR AIIMS BHUBANESHWAR | | | | | | | | | | | |
|--|--------------|------------------------------|----------|---------------|--------|-----------|-----------|------------------|------|----------------------------------|------------------|
| BLOCK | FLOOR | DESCRIPTION OF ROOM | ROOM NO | NO OF OUTLETS | | | | | | SINGLE ARM MOVABLE PENDANT | BEDHEAD PANEL |
| | | | | OXYGEN | VACUUM | AIR 4 BAR | AIR 7 BAR | NITROUS OXIDE | AGSS | | |
| HOSPITAL | SECOND FLOOR | WARD (4 BED) | HB 4303 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | WARD (4 BED) | HB 4311 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | WARD (4 BED) | HB 4312 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | ISOLATION ROOM | HB 4319 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | SECOND FLOOR | WARD (4 BED) | HB 4328 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | HDU (4 BED) | HB 4329 | 8 | 8 | 4 | 0 | 0 | 0 | 0 | 4 |
| HOSPITAL | SECOND FLOOR | WARD (4 BED) | HB 4330 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | WARD (4 BED) | HB 4338 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | WARD (4 BED) | HB 4339 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | ISOLATION ROOM | HB 4345 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | SECOND FLOOR | ISOLATION ROOM | HB 4360 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | SECOND FLOOR | WARD (4 BED) | HB 4365 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | WARD (4 BED) | HB 4366 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | WARD (4 BED) | HB 4373 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | HDU (4 BED) | HB 4374 | 8 | 8 | 4 | 0 | 0 | 0 | 0 | 4 |
| HOSPITAL | SECOND FLOOR | WARD (4 BED) | HB 4375 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | PRE OPERATIVE ROOM(4BED) | HB 4380 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SECOND FLOOR | POST OPERATIVE WARD(6BED) | HB 4414 | 12 | 12 | 6 | 0 | 0 | 0 | 0 | 6 |
| HOSPITAL | THIRD FLOOR | WARD (13 BED) | HB 5019 | 7 | 7 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | THIRD FLOOR | WARD (13 BED) | HB 5031 | 7 | 7 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | THIRD FLOOR | ISOLATION ROOM | HB 5032 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | THIRD FLOOR | ISOLATION ROOM | HB 5042 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | THIRD FLOOR | WARD (13 BED) | HB 5051 | 7 | 7 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | THIRD FLOOR | WARD (13 BED) | HB 5056 | 7 | 7 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | THIRD FLOOR | ISOLATION ROOM | HB 5061 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | THIRD FLOOR | ISOLATION ROOM | HB 5080 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | THIRD FLOOR | POST OPERATIVE WARD(6BED) | HB 5085 | 12 | 12 | 6 | 0 | 0 | 0 | 0 | 6 |
| HOSPITAL | THIRD FLOOR | PRE OPERATIVE WARD(4BED) | HB 5087 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 4 |
| HOSPITAL | THIRD FLOOR | WARD (13 BED) | HB 5133 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | THIRD FLOOR | ISOLATION ROOM | HB 5133A | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | THIRD FLOOR | ISOLATION ROOM | HB 5138A | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | THIRD FLOOR | WARD (13 BED) | HB 5138 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | THIRD FLOOR | ISOLATION ICU(7 BED) | HB 5142 | 14 | 14 | 7 | 0 | 0 | 0 | 0 | 7 |
| HOSPITAL | THIRD FLOOR | ISOLATION ICU(7 BED) | HB 5149 | 14 | 14 | 7 | 0 | 0 | 0 | 0 | 7 |
| HOSPITAL | THIRD FLOOR | ISOLATION ICU(7 BED) | HB 5152 | 14 | 14 | 7 | 0 | 0 | 0 | 0 | 7 |

| MEDICAL GAS OUTLETS FOR AIIMS BHUBANESHWAR | | | | | | | | | | | |
|--|-------------|--------------------------------|------------|---------------|--------|-----------|-----------|------------------|------|----------------------------------|------------------|
| BLOCK | FLOOR | DESCRIPTION OF ROOM | ROOM NO | NO OF OUTLETS | | | | | | SINGLE ARM MOVABLE PENDANT | BEDHEAD PANEL |
| | | | | OXYGEN | VACUUM | AIR 4 BAR | AIR 7 BAR | NITROUS OXIDE | AGSS | | |
| HOSPITAL | THIRD FLOOR | ISOLATION ICU(7 BED) | HB 5159 | 14 | 14 | 7 | 0 | 0 | 0 | 0 | 7 |
| HOSPITAL | THIRD FLOOR | WARD (4 BED) | HB 5180 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | THIRD FLOOR | WARD (4 BED) HDU | HB 5181 | 8 | 8 | 4 | 0 | 0 | 0 | 0 | 4 |
| HOSPITAL | THIRD FLOOR | WARD (4 BED) | HB 5182 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | THIRD FLOOR | WARD (4 BED) | HB 5190 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | THIRD FLOOR | WARD (4 BED) | HB 5191 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | THIRD FLOOR | ISOLATION ROOM | HB 5198 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | THIRD FLOOR | WARD 4 BEDDED | HB 5205 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | THIRD FLOOR | WARD (4 BED) HDU | HB 5206 | 8 | 8 | 4 | 0 | 0 | 0 | 0 | 4 |
| HOSPITAL | THIRD FLOOR | WARD (4 BED) | HB 5207 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | THIRD FLOOR | WARD (4 BED) | HB 5215 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | THIRD FLOOR | WARD (4 BED) | HB 5216 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | THIRD FLOOR | ISOLATION ROOM | HB 5221 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | THIRD FLOOR | ISOLATION ROOM | HB 5236 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | THIRD FLOOR | WARD (4 BED) | HB 5241 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | THIRD FLOOR | WARD (4 BED) | HB 5242 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | THIRD FLOOR | WARD (4 BED) | HB 5249 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | THIRD FLOOR | WARD (4 BED) HDU | HB 5250 | 8 | 8 | 4 | 0 | 0 | 0 | 0 | 4 |
| HOSPITAL | THIRD FLOOR | WARD (4 BED) | HB 5251 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | THIRD FLOOR | PRE OPERATIVE ROOM(4BED) | HB 5256 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | THIRD FLOOR | POST OPERATIVE WARD(6BED) | HB 5290 | 12 | 12 | 6 | 0 | 0 | 0 | 0 | 6 |
| HOSPITAL | FOURTH | WARD (13 BED) | HB 6004 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FOURTH | WARD (13 BED) | HB 6016 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FOURTH | ISOLATION ROOM | HB 6017 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FOURTH | ISOLATION ROOM | HB 6027 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FOURTH | WARD (13 BED) | HB 6040 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FOURTH | WARD (13 BED) | HB 6045 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FOURTH | ISOLATION ROOM | HB 6050 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FOURTH | ISOLATION ROOM | HB 6070 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FOURTH | POST OPERATIVE WARD (8 BED) | HB 6075 | 16 | 16 | 8 | 0 | 0 | 0 | 0 | 8 |
| HOSPITAL | FOURTH | PRE OPERATIVE WARD (4 BED) | HB 6077 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FOURTH | WARD (13 BED) | HB 6122 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FOURTH | ISOLATION ROOM | HB 6122(A) | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FOURTH | WARD (13 BED) | HB 6127 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FOURTH | ISOLATION ROOM | HB 6127(A) | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |

| MEDICAL GAS OUTLETS FOR AIIMS BHUBANESHWAR | | | | | | | | | | | |
|--|--------|-----------------------------|---------|---------------|--------|-----------|-----------|------------------|------|----------------------------------|------------------|
| BLOCK | FLOOR | DESCRIPTION OF ROOM | ROOM NO | NO OF OUTLETS | | | | | | SINGLE ARM MOVABLE PENDANT | BEDHEAD PANEL |
| | | | | OXYGEN | VACUUM | AIR 4 BAR | AIR 7 BAR | NITROUS OXIDE | AGSS | | |
| HOSPITAL | FOURTH | ISOLATION ICU(7 BED) | HB 6131 | 14 | 14 | 7 | 0 | 0 | 0 | 0 | 7 |
| HOSPITAL | FOURTH | ISOLATION ICU(7 BED) | HB 6138 | 14 | 14 | 7 | 0 | 0 | 0 | 0 | 7 |
| HOSPITAL | FOURTH | ISOLATION ICU(7 BED) | HB 6141 | 14 | 14 | 7 | 0 | 0 | 0 | 0 | 7 |
| HOSPITAL | FOURTH | ISOLATION ICU(7 BED) | HB 6148 | 14 | 14 | 7 | 0 | 0 | 0 | 0 | 7 |
| HOSPITAL | FOURTH | WARD (4 BED) | HB 6169 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FOURTH | HDU (4 BED) | HB 6170 | 8 | 8 | 4 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FOURTH | WARD (4 BED) | HB 6171 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FOURTH | WARD (4 BED) | HB 6179 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FOURTH | WARD (4 BED) | HB 6180 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FOURTH | ISOLATION ROOM | HB 6187 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FOURTH | WARD (4 BED) | HB 6194 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FOURTH | HDU (4 BED) | HB 6195 | 8 | 8 | 4 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FOURTH | WARD (4 BED) | HB 6196 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FOURTH | WARD (4 BED) | HB 6204 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FOURTH | WARD (4 BED) | HB 6205 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FOURTH | ISOLATION ROOM | HB 6210 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FOURTH | ISOLATION ROOM | HB 6225 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FOURTH | WARD (4 BED) | HB 6230 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FOURTH | WARD (4 BED) | HB 6231 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FOURTH | WARD (4 BED) | HB 6238 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FOURTH | HDU (4 BED) | HB 6239 | 8 | 8 | 4 | 0 | 0 | 0 | 0 | 4 |
| HOSPITAL | FOURTH | WARD (4 BED) | HB 6240 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FOURTH | PRE OPERATIVE ROOM (4 BED) | HB 6245 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FOURTH | POST OPERATIVE WARD (8 BED) | HB 6279 | 16 | 16 | 8 | 0 | 0 | 0 | 0 | 8 |
| HOSPITAL | FIFTH | WARD (13 BED) | HB 7004 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIFTH | WARD (13 BED) | HB 7015 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIFTH | ISOLATION ROOM | HB 7016 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FIFTH | ISOLATION ROOM | HB 7026 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FIFTH | WARD (13 BED) | HB 7035 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIFTH | WARD (13 BED) | HB 7040 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIFTH | ISOLATION ROOM | HB 7045 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FIFTH | ISOLATION ROOM | HB 7065 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FIFTH | WARD (13 BED) | HB 7079 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIFTH | WARD (13 BED) | HB 7084 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIFTH | ISOLATION ROOM | HB 7089 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FIFTH | ISOLATION ROOM | HB 7109 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FIFTH | WARD (4 BED) | HB 7117 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |

| MEDICAL GAS OUTLETS FOR AIIMS BHUBANESHWAR | | | | | | | | | | | |
|--|-------|---------------------|---------|---------------|--------|-----------|-----------|------------------|------|----------------------------------|------------------|
| BLOCK | FLOOR | DESCRIPTION OF ROOM | ROOM NO | NO OF OUTLETS | | | | | | SINGLE ARM MOVABLE PENDANT | BEDHEAD PANEL |
| | | | | OXYGEN | VACUUM | AIR 4 BAR | AIR 7 BAR | NITROUS OXIDE | AGSS | | |
| HOSPITAL | FIFTH | HDU (4 BED) | HB 7118 | 8 | 8 | 4 | 0 | 0 | 0 | 0 | 4 |
| HOSPITAL | FIFTH | WARD (4 BED) | HB 7119 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIFTH | WARD (4 BED) | HB 7127 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIFTH | WARD (4 BED) | HB 7128 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIFTH | ISOLATION ROOM | HB 7135 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FIFTH | WARD (4 BED) | HB 7168 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIFTH | HDU (4 BED) | HB 7169 | 8 | 8 | 4 | 0 | 0 | 0 | 0 | 4 |
| HOSPITAL | FIFTH | WARD (4 BED) | HB 7170 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIFTH | WARD (4 BED) | HB 7178 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIFTH | WARD (4 BED) | HB 7179 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIFTH | ISOLATION ROOM | HB 7184 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FIFTH | ISOLATION ROOM | HB 7197 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | FIFTH | WARD (4 BED) | HB 7213 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | FIFTH | HDU (4 BED) | HB 7214 | 8 | 8 | 4 | 0 | 0 | 0 | 0 | 4 |
| HOSPITAL | FIFTH | WARD (4 BED) | HB 7215 | 2 | 2 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SIXTH | WARD (13 BED) | HB 8004 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SIXTH | WARD (13 BED) | HB 8015 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SIXTH | ISOLATION ROOM | HB 8016 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | SIXTH | ISOLATION ROOM | HB 8026 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | SIXTH | WARD (13 BED) | HB 8035 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SIXTH | WARD (13 BED) | HB 8040 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SIXTH | ISOLATION ROOM | HB 8045 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | SIXTH | ISOLATION ROOM | HB 8065 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | SIXTH | WARD (13 BED) | HB 8074 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SIXTH | WARD (13 BED) | HB 8079 | 8 | 8 | 0 | 0 | 0 | 0 | 0 | 0 |
| HOSPITAL | SIXTH | ISOLATION ROOM | HB 8084 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| HOSPITAL | SIXTH | ISOLATION ROOM | HB 8104 | 2 | 2 | 1 | 0 | 0 | 0 | 0 | 1 |
| TOTAL | | | | 1092 | 1092 | 291 | 0 | 2 | 2 | 2 | 280 |