

<u>Amendment -1</u>		
Technical Queries pertaining to Tender : Construction of Compound wall for JIPMER Campus, Puducherry		
Sr. No.	Pre-bid Queries by Bidders	Reply By HLL
1	Whether diagonals are to be provided for the barbed wire fencing	Should follow the specifications in price bid and the detailed drawing will be uploaded in website
2	Whether the dismantling of the existing compound wall has to be done by the bidder.	Dismantling the existing compound wall, clearing jungle and uprooting of trees wherever required is in the scope of work of the qualified bidder. This has been mentioned in the tender document in special conditions- Part III A
3	Whether the structural details are to be provided by the bidder.	The structural members including foundation has to be designed by the construction agency and has to be vetted by Engineering college in coordination with HLL. This has been mentioned in the tender document in special conditions- Part III A
4	The make for reinforcement	Bidders should supply the makes mentioned in the tender document in special conditions- Part III A
5	Due to shortage of river sand ,whether M sand can be used instead of river sand.	M sand can be used, provided design mix to comply with IS 10262 & CPWD spec shall be submitted and approved by HLL for concrete Grade M 30
6	Requested to extend the date of submission of bids .	The revised date for submission of bids is 16.12.2013 at 1400hrs at ID Division, Thiruvananthapuram

Technical Queries pertaining to Tender : Construction of Compound wall for JIPMER Campus, Puducherry		
Sr. No.	Pre-bid Queries by Bidders	Reply By HLL
	<u>EXISTING CLAUSE NO:20 of Section -II Information & Instructions for Applicants in the Technical bid</u>	<u>CHANGED CLAUSE:-</u>
7	All disputes arising shall be subject to the jurisdiction of the appropriate court at Thiruvananthapuram,India and will be governed by the laws of India.	All disputes arising shall be subject to the jurisdiction of the appropriate court at Puducherry,India and will be governed by the laws of India.