



NOTES:
1. ANY DISCREPANCY IN THE DRAWING, SHALL BE INFORMED TO THE CONSULTANTS IMMEDIATELY.

2. FIRE ESCAPE STAIRCASE AT TRAVEL DISTANCE OF 30.0M, AND WEIRISER PER STAIRCASE OR PER 1000 Sqm. FOR FLOORS ABOVE GROUND LEVEL
3. SAND BUCKETS SHALL BE PROVIDED AT CAR PARKING AREA, 2 Nos FOR 8 CARS
4. ABC TYPE FIRE EXTINGUISHER SHALL BE PROVIDED AT TRANSFORMER YARDS, GENERATOR ROOM ENTRANCE, ELECTRICAL ROOM ENTRANCE, HSD YARDS & CAR PARKING AREA 1 NO PER 8 CARS
5. ALL ISOLATING VALVES SHOULD BE OF LOCKABLE TYPE.
6. STAIRCASES HEADROOM HEIGHT WILL BE 2.20M .

web : www.lifecarehll.com

sivababu2005@yahoo.co.in

STRUCTURAL CONSULTANTS:

.com

FIGHTING LAYOUT

C:\Users\HLL\Desktop\NEW FINE FIGHTING DRAWING\HLL Project Fire Fighting Drawing-2010.dwg