

Addendum No: 1

to

Tender no. HLL/IDS/16/25/ Power supply-SQ/JIPMER dated: 28.12.2016

for

Power supply connection to staff quarters of Type-II, Type-IV and Type-V

at

JAWAHARLAL INSTITUTE OF POSTGRADUATE MEDICAL EDUCATION & RESEARCH , PUDUCHERRY

Ref: Tender no. HLL/IDS/16/25/ Power supply-SQ/JIPMER dated: 28.12.2016

Additional information/clarification to Technical Specifications:

The following additional information to technical specification shall be read with the technical points mentioned in the bid document:

In Price bid BOQ Sr. No 2.1& 2.2 Transformer:

Requirement is energy Efficient Transformer of 315 KVA and 500 KVA to be provided as per IS: 1180.

In price bid BOQ Sr. No 10 (a) & (b) Main LT Panel boards outgoing feeders:

Requirement is 4 Nos of 400A MCCB with 50KA Breaking capacity with electromagnetic release for ambient temperature is 40 Degree Celsius

All other terms and conditions of the tender document remain unaltered.
