

GAS OULETS FOR HOSPITAL, AIIMS RISHIKESH										
LEVEL	DESCRIPTION OF ROOM	ROOM NO	NO OF OULETS						SINGLE ARM MOVABLE PENDANT	BEDHEAD PANEL
			OXYGEN	VACUUM	AIR 4 bar	AIR 7 bar	N2O	AGSS		
GROUND	COBALT THERAPY	HB 1024	1	1	0	0	0	0	0	0
GROUND	SIMULATOR CT	HB 1028	1	1	0	0	0	0	0	0
GROUND	SINGLE ROOM	HB 1036	1	1	0	0	0	0	0	0
GROUND	CUBICLES FOR BRACHYTHERAPY	HB 1037	1	1	0	0	0	0	0	0
GROUND	CHEMOTHERAPY(4 BED)	HB 1046	4	4	0	0	0	0	0	0
GROUND	CHEMOTHERAPY(4 BED)	HB 1049	4	4	0	0	0	0	0	0
GROUND	CHEMOTHERAPY(4 BED)	HB 1063	4	4	0	0	0	0	0	0
FIRST FLOOR	DIALYSIS ISOLATION ROOM	HB 2005	2	2	1	0	0	0	0	1
FIRST FLOOR	DIALYSIS ROOM	HB 2006	4	4	2	0	0	0	0	2
FIRST FLOOR	DIALYSIS ROOM	HB 2012	4	4	2	0	0	0	0	2
FIRST FLOOR	CT SCAN ROOM	HB 2020	1	1	0	0	0	0	0	0
FIRST FLOOR	MRI ROOM	HB 2032	1	1	0	0	0	0	0	0
SECOND	GYNAECOLOGY WARD(6 BED)	HB 3002	4	4	0	0	0	0	0	0
SECOND	GYNAECOLOGY WARD(6 BED)	HB 3003	4	4	0	0	0	0	0	0
SECOND	GYNAECOLOGY WARD(6 BED)	HB 3006	4	4	0	0	0	0	0	0
SECOND	GYNAECOLOGY WARD(6 BED)	HB 3009	4	4	0	0	0	0	0	0
SECOND	GYNAECOLOGY ISOLATION ROOM	HB 3015	2	2	1	0	0	0	0	1
SECOND	GYNAECOLOGY WARD(6 BED)	HB 3016	4	4	0	0	0	0	0	0
SECOND	GYNAECOLOGY WARD(6 BED)	HB 3019	4	4	0	0	0	0	0	0
SECOND	STATION(6BED)	HB 3030	12	12	6	0	0	0	0	6

LEVEL	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS						SINGLE ARM MOVABLE PENDANT	BEDHEAD PANEL
			OXYGEN	VACUUM	AIR 4 bar	AIR 7 bar	N2O	AGSS		
SECOND	ISOLATION ROOM	HB 3048	2	2	1	0	0	0	0	1
SECOND	DELIVERY SUITS	HB 3057	2	2	2	0	0	0	0	0
SECOND	LABOUR RECOVERY(6BED)	HB 3077	12	12	6	0	0	0	0	1
SECOND	GYNAECOLOGY WARD(6 BED)	HB 3084	4	4	0	0	0	0	0	0
SECOND	GYNAECOLOGY WARD(6 BED)	HB 3087	4	4	0	0	0	0	0	0
SECOND	ISOLATION ROOM	HB 3088	2	2	1	0	0	0	0	1
SECOND	GYNAECOLOGY WARD(6 BED)	HB 3093	4	4	0	0	0	0	0	0
SECOND	GYNAECOLOGY WARD(6 BED)	HB 3096	4	4	0	0	0	0	0	0
SECOND	GYNAECOLOGY WARD(6 BED)	HB 3099	4	4	0	0	0	0	0	0
SECOND	GYNAECOLOGY WARD(6 BED)	HB 3100	4	4	0	0	0	0	0	0
THIRD	SURGERY WARD(6 BED)	HB 4001	4	4	0	0	0	0	0	0
THIRD	SURGERY WARD(6 BED)	HB 4002	4	4	0	0	0	0	0	0
THIRD	SURGERY WARD(6 BED)	HB 4003	4	4	0	0	0	0	0	0
THIRD	SURGERY WARD(6 BED)	HB 4006	4	4	0	0	0	0	0	0
THIRD	ISOLATION ROOM	HB 4014	2	2	1	0	0	0	0	1
THIRD	SURGERY WARD(6 BED)	HB 4016	4	4	0	0	0	0	0	0
THIRD	SURGERY WARD(6 BED)	HB 4020	4	4	0	0	0	0	0	0
THIRD	SURGERY WARD(6 BED)	HB 4025	4	4	0	0	0	0	0	0
THIRD	SURGERY WARD(6 BED)	HB 4036	4	4	0	0	0	0	0	0
THIRD	SURGERY WARD(6 BED)	HB 4039	4	4	0	0	0	0	0	0

LEVEL	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS						SINGLE ARM MOVABLE PENDANT	BEDHEAD PANEL
			OXYGEN	VACUUM	AIR 4 bar	AIR 7 bar	N2O	AGSS		
THIRD	SURGERY WARD(6 BED)	HB 4045	4	4	0	0	0	0	0	0
THIRD	SURGERY WARD(6 BED)	HB 4049	4	4	0	0	0	0	0	0
THIRD	ISOLATION ROOM	HB 4050	2	2	1	0	0	0	0	1
THIRD	SURGERY WARD(6 BED)	HB 4059	4	4	0	0	0	0	0	0
THIRD	SURGERY WARD(6 BED)	HB 4062	4	4	0	0	0	0	0	0
THIRD	ISOLATION ROOM	HB 4067	2	2	1	0	0	0	0	1
THIRD	SURGERY WARD(6 BED)	HB 4068	4	4	0	0	0	0	0	0
THIRD	SURGERY WARD(6 BED)	HB 4072	4	4	0	0	0	0	0	0
THIRD	SURGERY WARD(6 BED)	HB 4079	4	4	0	0	0	0	0	0
THIRD	SURGERY WARD(6 BED)	HB 4082	4	4	0	0	0	0	0	0
THIRD	SURGERY WARD(6 BED)	HB 4088	4	4	0	0	0	0	0	0
THIRD	SURGERY WARD(6 BED)	HB 4092	4	4	0	0	0	0	0	0
THIRD	ISOLATION ROOM	HB 4093	2	2	1	0	0	0	0	1
FOURTH	CARDIOLOGY WARD(4 BED)	HB 5002	2	2	0	0	0	0	0	0
FOURTH	CARDIOLOGY WARD(4 BED)	HB 5003	2	2	0	0	0	0	0	0
FOURTH	CARDIOLOGY WARD(4 BED)	HB 5006	2	2	0	0	0	0	0	0
FOURTH	CARDIOLOGY WARD(4 BED)	HB 5009	2	2	0	0	0	0	0	0
FOURTH	ISOLATION ROOM	HB 5014	2	2	1	0	0	0	0	1
FOURTH	CARDIOLOGY WARD(4 BED)	HB 5015	2	2	0	0	0	0	0	0
FOURTH	CARDIOLOGY WARD(4 BED)	HB 5018	2	2	0	0	0	0	0	0
FOURTH	CCU(10 BED)	HB 5028	20	20	10	0	0	0	0	10

LEVEL	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS						SINGLE ARM MOVABLE PENDANT	BEDHEAD PANEL
			OXYGEN	VACUUM	AIR 4 bar	AIR 7 bar	N2O	AGSS		
FOURTH	ISOLATION ROOM	HB 5044	2	2	1	0	0	0	0	1
FOURTH	RESUSCITATION ROOM	HB 5050	2	2	1	0	0	0	0	1
FOURTH	CATH LAB	HB 5053	2	2	2	0	0	0	0	0
FOURTH	CATH LAB	HB 5066	2	2	2	0	0	0	0	0
FOURTH	CATH LAB	HB 5067	2	2	2	0	0	0	0	0
FOURTH	RECOVERY ROOM(6 BED)	HB 5068	12	12	6	0	0	0	0	6
FOURTH	CARDIOLOGY WARD(4 BED)	HB 5075	2	2	0	0	0	0	0	0
FOURTH	CARDIOLOGY WARD(4 BED)	HB 5078	2	2	0	0	0	0	0	0
FOURTH	ISOLATION ROOM	HB 5079	2	2	1	0	0	0	0	1
FOURTH	CARDIOLOGY WARD(4 BED)	HB 5083	2	2	0	0	0	0	0	0
FOURTH	CARDIOLOGY WARD(4 BED)	HB 5086	2	2	0	0	0	0	0	0
FOURTH	CARDIOLOGY WARD(4 BED)	HB 5089	2	2	0	0	0	0	0	0
FOURTH	CARDIOLOGY WARD(4 BED)	HB 5090	2	2	0	0	0	0	0	0
FIFTH	ICU(10 BED)	HB 6017	20	20	10	0	0	0	0	10
FIFTH	ISOLATION ROOM	HB 6018	2	2	1	0	0	0	0	1
FIFTH	RECOVERY ROOM(6 BED)	HB 6033	12	12	6	0	0	0	0	6
FIFTH	RECOVERY ROOM(6 BED)	HB 6070	12	12	6	0	0	0	0	6
FIFTH	RECOVERY ROOM(6 BED)	HB 6084	12	12	6	0	0	0	0	6
	<b>TOTAL</b>		<b>320</b>	<b>320</b>	<b>81</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>0</b>	<b>68</b>

GAS OULETS FOR OPD, AIIMS RISHIKESH										
LEVEL	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS						SINGLE ARM MOVABLE PENDANT	BEDHEAD PANEL
			OXYGEN	VACUUM	AIR 4 bar	AIR 7 bar	NITROUS OXIDE	AGSS		
GROUND	PMR WARD(6 BED)	OB 1029	4	4	0	0	0	0	0	0
GROUND	PMR WARD(6 BED)	OB 1030	4	4	0	0	0	0	0	0
GROUND	PMR WARD(6 BED)	OB 1046	4	4	0	0	0	0	0	0
GROUND	TRIAGE WARD(6 BED)	OB 1047	4	4	0	0	0	0	0	0
GROUND	TRIAGE MINOR OT	OB 1053	2	2	2	0	1	1	1	0
GROUND	TRIAGE(10 BED)	OB 1054	6	6	0	0	0	0	0	0
GROUND	RESUSITATION ROOM	OB 1071	2	2	1	0	0	0	0	1
GROUND	ISOLATION ROOM	OB 1072	2	2	1	0	0	0	0	1
GROUND	EMERGENCY OPD WARD (6 BED)	OB 1073	4	4	0	0	0	0	0	0
THIRD	GENERAL MEDICINE WARD(6 BED)	OB 4002	4	4	0	0	0	0	0	0
THIRD	GENERAL MEDICINE WARD(6 BED)	OB 4003	4	4	0	0	0	0	0	0
THIRD	GENERAL MEDICINE WARD(6 BED)	OB 4006	4	4	0	0	0	0	0	0
THIRD	GENERAL MEDICINE WARD(6 BED)	OB 4009	4	4	0	0	0	0	0	0
THIRD	ISOLATION ROOM	OB 4013	2	2	1	0	0	0	0	1
THIRD	GENERAL MEDICINE WARD(6 BED)	OB 4014	4	4	0	0	0	0	0	0
THIRD	GENERAL MEDICINE WARD(6 BED)	OB 4017	4	4	0	0	0	0	0	0
THIRD	GASTROENTROLOGY WARD(6 BED)	OB 4026(A)	4	4	0	0	0	0	0	0
THIRD	GASTROENTROLOGY WARD(6 BED)	OB 4029	4	4	0	0	0	0	0	0
THIRD	GASTROENTROLOGY WARD(6 BED)	OB 4040	4	4	0	0	0	0	0	0
THIRD	GASTROENTROLOGY WARD(6 BED)	OB 4043	4	4	0	0	0	0	0	0
THIRD	GASTROENTROLOGY WARD(6 BED)	OB 4031	4	4	0	0	0	0	0	0
THIRD	ISOLATION ROOM	OB 4044	2	2	1	0	0	0	0	1
THIRD	GASTROENTROLOGY WARD(6 BED)	OB 4032	4	4	0	0	0	0	0	0
THIRD	GASTROENTROLOGY WARD(6 BED)	OB 4046	4	4	0	0	0	0	0	0

LEVEL	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS						SINGLE ARM MOVABLE PENDANT	BEDHEAD PANEL
			OXYGEN	VACUUM	AIR 4 bar	AIR 7 bar	NITROUS OXIDE	AGSS		
THIRD	GASTROENTROLOGY WARD(6 BED)	OB 4047	4	4	0	0	0	0	0	0
THIRD	ISOLATION ROOM	OB 4049	2	2	1	0	0	0	0	1
THIRD	UROLOGY WARD(6 BED)	OB 4050	4	4	0	0	0	0	0	0
THIRD	UROLOGY WARD(6 BED)	OB 4053	4	4	0	0	0	0	0	0
THIRD	UROLOGY WARD(6 BED)	OB 4060	4	4	0	0	0	0	0	0
THIRD	UROLOGY WARD(6 BED)	OB 4063	4	4	0	0	0	0	0	0
THIRD	RESPIRATORY MEDICINE WARD(6 BED)	OB 4083	4	4	0	0	0	0	0	0
THIRD	RESPIRATORY MEDICINE WARD	OB 4084	4	4	0	0	0	0	0	0
THIRD	ISOLATION ROOM	OB 4074	2	2	1	0	0	0	0	1
THIRD	RESPIRATORY MEDICINE WARD(6 BED)	OB 4070	4	4	0	0	0	0	0	0
THIRD	RESPIRATORY MEDICINE WARD(6 BED)	OB 4073	4	4	0	0	0	0	0	0
THIRD	RESPIRATORY MEDICINE WARD(6 BED)	OB 4078	4	4	0	0	0	0	0	0
THIRD	RESPIRATORY MEDICINE WARD(6 BED)	OB 4081	4	4	0	0	0	0	0	0
FOURTH	DERMATOLOGY WARD (6BED)	OB 5002	4	4	0	0	0	0	0	0
FOURTH	DERMATOLOGY WARD (6BED)	OB 5003	4	4	0	0	0	0	0	0
FOURTH	DERMATOLOGY WARD (6BED)	OB 5006	4	4	0	0	0	0	0	0
FOURTH	DERMATOLOGY WARD (6BED)	OB 5009	4	4	0	0	0	0	0	0
FOURTH	ISOLATION ROOM	OB 5014	2	2	1	0	0	0	0	1
FOURTH	DERMATOLOGY WARD (6BED)	OB 5015	4	4	0	0	0	0	0	0
FOURTH	DERMATOLOGY WARD (6BED)	OB 5018	4	4	0	0	0	0	0	0
FOURTH	PSYCHIATRY WARD (6BED)	OB 5026	4	4	0	0	0	0	0	0
FOURTH	PSYCHIATRY WARD (6BED)	OB 5029	4	4	0	0	0	0	0	0
FOURTH	PSYCHIATRY WARD (6BED)	OB 5040	4	4	0	0	0	0	0	0

LEVEL	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS						SINGLE ARM MOVABLE PENDANT	BEDHEAD PANEL
			OXYGEN	VACUUM	AIR 4 bar	AIR 7 bar	NITROUS OXIDE	AGSS		
FOURTH	PSYCHIATRY WARD (6BED)	OB 5043	4	4	0	0	0	0	0	0
FOURTH	PSYCHIATRY WARD (6BED)	OB 5032	4	4	0	0	0	0	0	0
FOURTH	PSYCHIATRY WARD (6BED)	OB 5033	4	4	0	0	0	0	0	0
FOURTH	ISOLATION ROOM	OB 5044	2	2	1	0	0	0	0	1
FOURTH	GYNAECOLOGYISOLATION ROOM	OB 5047	2	2	1	0	0	0	0	1
FOURTH	GYNAECOLOGY WARD(6BED)	OB 5087	4	4	0	0	0	0	0	0
FOURTH	GYNAECOLOGY WARD(6BED)	OB 5088	4	4	0	0	0	0	0	0
FOURTH	GYNAECOLOGY WARD(6BED)	OB 5058	4	4	0	0	0	0	0	0
FOURTH	GYNAECOLOGY WARD(6BED)	OB 5059	4	4	0	0	0	0	0	0
FOURTH	GYNAECOLOGY WARD(6BED)	OB 5048	4	4	0	0	0	0	0	0
FOURTH	GYNAECOLOGY WARD(6BED)	OB 5051	4	4	0	0	0	0	0	0
FOURTH	GYNAECOLOGY WARD(6BED)	OB 5062	4	4	0	0	0	0	0	0
FOURTH	GYNAECOLOGY WARD(6BED)	OB 5065	4	4	0	0	0	0	0	0
FOURTH	ISOLATION ROOM	OB 5077	2	2	1	0	0	0	0	1
FOURTH	GYNAECOLOGY WARD(6BED)	OB 5073	4	4	0	0	0	0	0	0
FOURTH	GYNAECOLOGY WARD(6BED)	OB 5076	4	4	0	0	0	0	0	0
FOURTH	GYNAECOLOGY WARD(6BED)	OB 5081	4	4	0	0	0	0	0	0
FOURTH	GYNAECOLOGY WARD(6BED)	OB 5084(A)	4	4	0	0	0	0	0	0
FIFTH	NEUROLOGY WARD(6BED)	OB 6002	4	4	0	0	0	0	0	0
FIFTH	NEUROLOGY WARD(6BED)	OB 6003	4	4	0	0	0	0	0	0

LEVEL	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS						SINGLE ARM MOVABLE PENDANT	BEDHEAD PANEL
			OXYGEN	VACUUM	AIR 4 bar	AIR 7 bar	NITROUS OXIDE	AGSS		
FIFTH	NEUROLOGY WARD(6BED)	OB 6006	4	4	0	0	0	0	0	0
FIFTH	NEUROLOGY WARD(6BED)	OB 6009	4	4	0	0	0	0	0	0
FIFTH	ISOLATION ROOM	OB 6015	2	2	1	0	0	0	0	1
FIFTH	NEUROLOGY WARD(6BED)	OB 6017	4	4	0	0	0	0	0	0
FIFTH	NEUROLOGY WARD(6BED)	OB 6019	4	4	0	0	0	0	0	
FIFTH	GASTROENTEROLOGY PRIVATE ROOM	OB 6027	1	1	0	0	0	0	0	0
FIFTH	GASTROENTEROLOGY PRIVATE ROOM	OB 6029	1	1	0	0	0	0	0	0
FIFTH	GASTROENTEROLOGY PRIVATE ROOM	OB 6033	1	1	0	0	0	0	0	0
FIFTH	GASTROENTEROLOGY WARD(6BED)	OB 6035	4	4	0	0	0	0	0	0
FIFTH	GASTROENTEROLOGY WARD(6BED)	OB 6038	4	4	0	0	0	0	0	0
FIFTH	PRIVATE ROOM	OB 6043	1	1	0	0	0	0	0	0
FIFTH	PRIVATE ROOM	OB 6044	1	1	0	0	0	0	0	0
FIFTH	PRIVATE ROOM	OB 6049	1	1	0	0	0	0	0	0
FIFTH	PRIVATE ROOM	OB 6051	1	1	0	0	0	0	0	0
FIFTH	ENT/ OPHTHALMOLOGY WARD 6 BED	OB 6054	4	4	0	0	0	0	0	0
FIFTH	ENT/ OPHTHALMOLOGY WARD 6 BED	OB 6055	4	4	0	0	0	0	0	0
FIFTH	ISOLATION ROOM	OB 6067	2	2	1	0	0	0	0	1
FIFTH	WARD 6 BED	OB 6058	4	4	0	0	0	0	0	0
FIFTH	WARD 6 BED	OB 6061	4	4	0	0	0	0	0	0
FIFTH	WARD 6 BED	OB 6068	4	4	0	0	0	0	0	0
FIFTH	WARD 6 BED	OB 6071	4	4	0	0	0	0	0	0
FIFTH	ORTHO WARD(6 BED)	OB 6098	4	4	0	0	0	0	0	0
FIFTH	ORTHO WARD(6 BED)	OB 6099	4	4	0	0	0	0	0	0
FIFTH	ISOLATION ROOM	OB 6086	2	2	1	0	0	0	0	1
FIFTH	ORTHO WARD(6 BED)	OB 6082	4	4	0	0	0	0	0	0
FIFTH	ORTHO WARD(6 BED)	OB 6085	4	4	0	0	0	0	0	0
FIFTH	ORTHO WARD(6 BED)	OB 6092	4	4	0	0	0	0	0	0
FIFTH	ORTHO WARD(6 BED)	OB 6095	4	4	0	0	0	0	0	0
	<b>TOTAL</b>		<b>333</b>	<b>333</b>	<b>15</b>	<b>0</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>13</b>

GAS OULETS FOR TRAUMA, AIIMS RISHIKESH										
LEVEL	DESCRIPTION OF ROOM	ROOM NO	NO OF OULETS						SINGLE ARM MOVABLE	BEDHEAD PANEL
			OXYGEN	VACUUM	AIR 4 bar	AIR 7 bar	N2O	AGSS		
GROUND	CT SCAN ROOM	TB 1020	1	1	0	0	0	0	0	0
GROUND	MRI ROOM	TB 1027	1	1	0	0	0	0	0	0
GROUND	POST OPERATIVE WARD(4 BED)	TB 1048	8	8	4	0	0	0	0	4
GROUND	DISASTER WARD(10 BED)	TB 1053	6	6	0	0	0	0	0	0
GROUND	TRIAGE(8 BED)	TB 1055	6	6	0	0	0	0	0	0
GROUND	TRIAGE(8 BED)	TB 1056	6	6	0	0	0	0	0	0
GROUND	EMERGENCY MINOR OT	TB 1064	2	2	2	0	1	1	1	0
GROUND	RESUSCITATION ROOM	TB 1065	2	2	1	0	0	0	0	1
FIRST	VIP ROOM	TB 2001	1	1	0	0	0	0	0	0
FIRST	PRIVATE ROOM	TB 2003	1	1	0	0	0	0	0	0
FIRST	PRIVATE ROOM	TB 2005	1	1	0	0	0	0	0	0
FIRST	PRIVATE ROOM	TB 2007	1	1	0	0	0	0	0	0
FIRST	PRIVATE ROOM	TB 2009	1	1	0	0	0	0	0	0
FIRST	PRIVATE ROOM	TB 2011	1	1	0	0	0	0	0	0
FIRST	PRIVATE ROOM	TB 2017	1	1	0	0	0	0	0	0
FIRST	PRIVATE ROOM	TB 2019	1	1	0	0	0	0	0	0
FIRST	PRIVATE ROOM	TB 2020	1	1	0	0	0	0	0	0
FIRST	PRIVATE ROOM	TB 2021	1	1	0	0	0	0	0	0
FIRST	WARD(6 BED)	TB 2026	4	4	0	0	0	0	0	0
FIRST	WARD(6 BED)	TB 2029	4	4	0	0	0	0	0	0
FIRST	WARD(6 BED)	TB 2042	4	4	0	0	0	0	0	0
FIRST	WARD(6 BED)	TB 2045	4	4	0	0	0	0	0	0
FIRST	ISOLATION ROOM	TB 2046	2	2	1	0	0	0	0	1
FIRST	WARD(6 BED)	TB 2050	4	4	0	0	0	0	0	0
FIRST	WARD(6 BED)	TB 2053	4	4	0	0	0	0	0	0
FIRST	ISOLATION ROOM	TB 2057	2	2	1	0	0	0	0	1
FIRST	WARD(6 BED)	TB 2058	4	4	0	0	0	0	0	0
FIRST	WARD(6 BED)	TB 2061	4	4	0	0	0	0	0	0
FIRST	PRIVATE ROOM	TB 2070	1	1	0	0	0	0	0	0
FIRST	PRIVATE ROOM	TB 2072	1	1	0	0	0	0	0	0
FIRST	PRIVATE ROOM	TB 2074	1	1	0	0	0	0	0	0
FIRST	PRIVATE ROOM	TB 2076	1	1	0	0	0	0	0	0
FIRST	PRIVATE ROOM	TB 2078	1	1	0	0	0	0	0	0
FIRST	VIP ROOM	TB 2079	1	1	0	0	0	0	0	0
FIRST	PRIVATE ROOM	TB 2080	1	1	0	0	0	0	0	0
FIRST	PRIVATE ROOM	TB 2082	1	1	0	0	0	0	0	0
FIRST	PRIVATE ROOM	TB 2084	1	1	0	0	0	0	0	0

LEVEL	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS						SINGLE ARM MOVABLE	BEDHEAD PANEL
			OXYGEN	VACUUM	AIR 4 bar	AIR 7 bar	N2O	AGSS		
FIRST	PRIVATE ROOM	TB 2085	1	1	0	0	0	0	0	0
SECOND	ICU&NURSE STATION(10 BED)	TB 3033	20	20	10	0	0	0	0	10
SECOND	ISOLATION ROOM	TB 3050	2	2	1	0	0	0	0	1
SECOND	RECOVERY ROOM(6 BED)	TB 3076	12	12	6	0	0	0	0	6
	<b>TOTAL</b>		<b>122</b>	<b>122</b>	<b>26</b>	<b>0</b>	<b>1</b>	<b>1</b>	<b>1</b>	<b>24</b>

BLOCK	NO OF OUTLETS						SINGLE ARM MOVABLE PENDANT	BEDHEAD PANEL
	OXYGEN	VACUUM	AIR 4 bar	AIR 7 bar	N2O	AGSS		
TRAUMA	122	122	26	0	1	1	1	24
OPD	333	333	15	0	1	1	1	13
HOSPITAL	320	320	81	0	0	0	0	68
TOTAL	775	775	122	0	2	2	2	105