

एचएलएल लाइफकेयर लिमिटेड **HLL LIFECARE LIMITED**
भारतसर्कार का उद्यम (**A GOVT.OF INDIA ENTERPRISE**)
पेरूरकडा.पि.ओ.. **PEROORKADA. P.O,**

तिरुवनंतपुरम-695005 **THIRUVANANTHAPURAM-695 005**
PHONE NO: 0471 2437270 / 2539329

EMAIL: materialspt@lifecarehll.com/materialsnt@gmail.com

e-Tender No: PUR/08/R1/PQ/SITC 180 TR CHILLER/2021-22

Dated:26.06.2021

AMENDMENT – 1

Dated: 09.07.2021

Consider below mentioned conditions as a part of e-Tender No: PUR/08/R1/PQ/SITC 180 TR CHILLER/2021-22

1. Wherever twin compressors are mentioned in the tender document, Bidders are requested to read it as “Single compressor with twin screw”.
2. Fully automatic star-delta starters for all pumps according to capacity of pumps (make L&T) and all interconnecting cables shall be under the scope of bidder.

Above mentioned condition in page 27 (Sl.No.2) stands deleted and will be under the scope of HLL. However secondary pumping system with VFD panel, PLC controllers, will be under the scope of bidder.

3. Pump make mentioned in page 27 (Sl.No.2) shall be read as **Grundfos/Xylem**.

4. Make of cooling tower - **ADVANCE / EVAPROV/MIHIR**

5. In **COMPREHENSIVE ANNUAL MAINTENANCE PACKAGE** in tender document (Page.No.55, First point) - Primary and Secondary Pumps (2 no's) may be read as 4 No's each.

6. In page .No.48 (Point.No.16-(h)) of the tender document “power consumption figures in KW/TR at 10%,20%,30%,40%,50%,60%,70%,80%,90% & 100%” may read as 25% 150%,75% &100%.

7. In page .No.42 of the tender document (Point.No.5) “The lubrication system shall be forced type by pump” may read as Lubrication system shall be differential pressure.

8. Cooling tower to be selected based on the capacity of chiller + additional 10 % of chiller tonnage. (New condition).

9. Wherever OEM is mentioned in the tender document read the same as OEM or Authorized dealer of OEM. Authorized dealers who participate in the tender must furnish MoU or certificate of dealership with OEM valid for at least 1 year. Those bidders failing to produce MoU or certificate of dealership will be disqualified. (New condition).

10. Sl No 5 in Minimum Eligibility criteria may be read as Bidders or their authorized service representative firm must have their service personnel in Trivandrum and full-fledged office in Kerala within 250 kms from Trivandrum, with trained service engineers and full-fledged service facilities so as to attend breakdown calls immediately on request. Details of service personnel and trained engineers should be furnished.

11. Schedule- A , 2(c) Secondary Pump-4 nos. Specification includes following points also. Secondary Chilled water Pumps with VFD(Variable Speed-The pump selected for variable speed drive shall be capable of performing satisfactorily over a wide range of speed, allowing a speed variation from

एचएलएल लाइफकेयर लिमिटेड **HLL LIFECARE LIMITED**
भारतसर्कार का उद्यम (**A GOVT.OF INDIA ENTERPRISE**)
पेरूरकडा.पि.ओ.. **PEROORKADA. P.O,**
तिरुवनंतपुरम-695005 **THIRUVANANTHAPURAM-695 005**
PHONE NO: 0471 2437270 / 2539329

EMAIL: materialspt@lifecarehl.com/materialsnt@gmail.com

e-Tender No: PUR/08/R1/PQ/SITC 180 TR CHILLER/2021-22

Dated: 26.06.2021

20 % to 100 %) with dedicated microprocessor/PLC based pump controller with parallel pumping software duly downloaded, suitable to run on variable frequency drives as required and multiple differential pressure sensor / transmitters as necessary). VFD's and pump controllers shall be mounted in a CRCA powder coated control panel with front glass panel.

Preference to Make in India

Preference shall be given to local supplier as defined in public procurement (Preference to Make in India), Order 2017 as amended from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products. The minimum local content to qualify as a local supplier, should be as per relevant notification / order issued by the nodal ministry as available on the website of Department of Promotion of Industries and Internal Trade (DPIIT). If the bidder wants to avail the Purchase preference, the bidder must upload a certificate from the OEM regarding the percentage of the local content and the details of locations at which the local value addition is made along with their bid, failing which no purchase preference shall be granted.

Verification of Local Content:

a) The supplier at the time of tender, bidding or solicitation shall be required to indicate percentage of local content and provide self certification that the items offered meets the local content requirement for supplier, as the case may be. They shall also give the details of the locations (s) at which the local value addition is made.

b) In case the bid value is more than Rs 10 Crore, the declaration relating to percentage of local content shall be certified by the statutory auditor or cost auditor, if the OEM is a company and by a practicing cost accountant or a chartered accountant for OEMs other than companies as per the Public Procurement (preference to Make-in -India) order 2017 and subsequent amendment dated 16.09.2020 and any other amendments which may be made from time to time and its subsequent Orders/Notifications issued by concerned Nodal Ministry for specific Goods/Products.

Rule 144 (xi) of the GFR regarding restrictions on procurement from a bidder of a which mandates the bidder from a country sharing land border with India

Regarding restrictions on procurement from a bidder of a country which shares a land border with India, any bidder from a country which shares a land border with India will be eligible to bid in this tender only if the bidder is registered with the Competent Authority. While participating in bid, Bidder has to undertake compliance of this and any false declaration and non-compliance of this would be a ground for immediate termination of the contract and further legal action in accordance with the laws.



GENERAL MANAGER (PURCHASE)

*Bidders may submit signed copy of this amendment along with Technical Bid