

HLL LIFECARE LIMITED

(A Government of India Enterprise)
Project Division, Peroorkada. PO,
Thiruvananthapuram – 695005,
Kerala, India
Ph: 0471 – 2437270, 2437884
Fax: 0471 – 2432898, 2432647

INVITATION FOR BIDS (IFB)

AMENDMENT NOTICE NO - 1

Sub: Providing 2 Nos. 1000KVA Diesel Generator sets (with Acoustic Enclosure as per CPCB norms) & all its accessories, necessary to deliver the rated output continuously for our new condom manufacturing facility at Rubber Park, Irapuram, Kochi – reg.

Ref: IFB Ref No.HLL/IP/IFC/DG/2013 dated 11-10-2013

Amendment Date: 30.10.2013

With reference to the above mentioned tender, the detailed technical specification of Diesel Generator Sets - Control Panel in Schedule III, Page No.33 may be read as follows:

CONTROL PANEL

Separate control panel as per Kerala State Electrical Inspectorate standards shall be supplied. The breaker on the control panel shall be of 1600A rating, having field settable external overload setting arrangement. The control panel shall have provision for termination of 1600 Amps TP+N sandwiched Al bus duct from top for entry and exit. The control panel shall have 4 pole ACB with thermal O/L and 24 volt DC shunt coil ; voltage controlled O/C relay; over voltage; under voltage; negative sequence, low set earth fault relay and REF/Differential relay. The panel shall also have Ammeter, Voltmeter, Frequency Meter, Power Factor Meter, Energy Meter and kVA meter. Adequate space shall also be provided at the bottom of the panel to accommodate DIN rail mounted connectors to terminate control cables.

All other terms and conditions of the tender remain unchanged.

EXECUTIVE DIRECTOR (INTERNAL PROJECTS)