


 - PROPOSED AREA = 21.0 X 7.62 = 160 M²

SPECIFICATION	
	Sprinkler - 28 Nos
	Smoke Detector - 10 Nos
150 NB PIPE	35 Mtr
100 NB PIPE	26 Mtr
40 NB PIPE	40 Mtr
25 NB PIPE	48 Mtr

MATERIAL:		HLL Lifecare limited Thiruvananthapuram- 05	NO.OFF.
DRAWN BY:	FREDY JOSEPH	TITLE:-	LAYOUT OF FIRE HYDRANT FOR QUALITY RESERVE SAMPLE STORAGE AREA (COMMERCIAL COMPLEX BUILDING)
CHECKED BY:	GOKUL V BABU		
APPROVED BY:	VENUGOPAL .S		
DATE:	16-02-2021		
SCALE:			
ALL DIMENSIONS ARE IN M.M			Drg.no:- HLL- J-080-00
		SHEET NO: OF	REV:- DATE:-