

GAS OULETS FOR HOSPITAL, AIIMS PATNA								
LEVEL	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS					BEDHEAD PANEL
			OXYGEN	VACUUM	AIR 4 bar	NITROUS OXIDE	AGSS	
BASEMENT	MEDICAL ONCOLOGY & RADIOTHERAPY WARD 6 BED	HB 1003	4	4	0	0	0	0
BASEMENT	MEDICAL ONCOLOGY & RADIOTHERAPY WARD 6 BED	HB 1004	4	4	0	0	0	0
BASEMENT	MEDICAL ONCOLOGY & RADIOTHERAPY WARD 6 BED	HB 1005	4	4	0	0	0	0
BASEMENT	MEDICAL ONCOLOGY & RADIOTHERAPY WARD 6 BED	HB 1013	4	4	0	0	0	0
BASEMENT	MEDICAL ONCOLOGY & RADIOTHERAPY WARD 6 BED	HB 1019	4	4	0	0	0	0
BASEMENT	ETO ROOM	HB 1025	0	0	1	0	0	0
BASEMENT	SURGICAL ONCOLOGY WARD	HB 1087	4	4	0	0	0	0
BASEMENT	SURGICAL ONCOLOGY WARD	HB 1093	4	4	0	0	0	0
BASEMENT	SURGICAL ONCOLOGY WARD	HB 1101	4	4	0	0	0	0
BASEMENT	SURGICAL ONCOLOGY WARD	HB 1102	4	4	0	0	0	0
BASEMENT	SURGICAL ONCOLOGY WARD	HB 1103	4	4	0	0	0	0
GROUND	WARD -6 BED-ORTHO	HB 2004	4	4	0	0	0	0
GROUND	WARD -6 BED-ORTHO	HB 2005	4	4	0	0	0	0
GROUND	WARD -6 BED-ORTHO	HB 2006	4	4	0	0	0	0
GROUND	WARD -6 BED-ORTHO	HB 2012	4	4	0	0	0	0
GROUND	WARD -6 BED-ORTHO	HB 2013	4	4	0	0	0	0
GROUND	WARD -6 BED-ORTHO	HB 2014	4	4	0	0	0	0
GROUND	WARD -6 BED-ORTHO	HB 2023	4	4	0	0	0	0
GROUND	WARD -6 BED-ORTHO	HB 2029	4	4	0	0	0	0
GROUND	WARD -6 BED-ORTHO	HB 2040	4	4	0	0	0	0
GROUND	WARD -6 BED-ORTHO	HB 2046	4	4	0	0	0	0
GROUND	WARD -6 BED-GYNEC	HB 2057	4	4	0	0	0	0
GROUND	WARD -6 BED-GYNEC	HB 2063	4	4	0	0	0	0

GAS OULETS FOR HOSPITAL, AIIMS PATNA								
LEVEL	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS					BEDHEAD PANEL
			OXYGEN	VACUUM	AIR 4 bar	NITROUS OXIDE	AGSS	
GROUND	NICU-4 BED	HB 2073	4	4	2	0	0	2
GROUND	POSTPARTUM ROOM	HB 2074	1	1	0	0	0	0
GROUND	OBSERVATION ROOM 2 BED	HB 2076	1	1	0	0	0	0
GROUND	ECLAMPSIA ROOM 2 BED	HB 2083	1	1	1	0	0	0
GROUND	ECLAMPSIA ROOM 2 BED	HB 2091	1	1	1	0	0	0
GROUND	LABOUR ROOM (2 BED)	HB 2092	1	1	0	0	0	0
GROUND	NURSERY 4 BED	HB 2093	4	4	0	0	0	0
GROUND	WARD -6 BED-GYNEC	HB 2103	4	4	0	0	0	0
GROUND	WARD -6 BED-GYNEC	HB 2104	4	4	0	0	0	0
GROUND	WARD -6 BED-GYNEC	HB 2105	4	4	0	0	0	0
GROUND	TRIAGE /RESUSCITATION AREA 6 BED	HB 2145	12	12	6	0	0	6
GROUND	EMERGENCY WARD 6 BED	HB 2148	4	4	0	0	0	0
GROUND	EMERGENCY WARD 6 BED	HB 2149	4	4	0	0	0	0
GROUND	DSA	HB 2169	1	1	0	0	0	0
GROUND	MRI	HB 2178	1	1	0	0	0	0
GROUND	CT SCAN	HB 2181	1	1	0	0	0	0
FIRST	WARD GENERAL MEDICINE 6 BED	HB 3003	4	4	0	0	0	0
FIRST	WARD GENERAL MEDICINE 6 BED	HB 3004	4	4	0	0	0	0
FIRST	WARD GENERAL MEDICINE 6 BED	HB 3005	4	4	0	0	0	0
FIRST	WARD GENERAL MEDICINE 6 BED	HB 3011	4	4	0	0	0	0
FIRST	WARD GENERAL MEDICINE 6 BED	HB 3012	4	4	0	0	0	0
FIRST	WARD GENERAL MEDICINE 6 BED	HB 3013	4	4	0	0	0	0
FIRST	WARD GENERAL MEDICINE 6 BED	HB 3021	4	4	0	0	0	0
FIRST	WARD GENERAL MEDICINE 6 BED	HB 3027	4	4	0	0	0	0
FIRST	WARD GENERAL MEDICINE 6 BED	HB 3038	4	4	0	0	0	0
FIRST	WARD GENERAL MEDICINE 6 BED	HB 3044	4	4	0	0	0	0
FIRST	POST PARTUM ROOM	HB 3056	2	2	0	0	0	0
FIRST	OBSERVATION ROOM	HB 3059	1	1	0	0	0	0
FIRST	LABOUR ROOM (2 BED)	HB 3067	2	2	0	0	0	0
FIRST	LABOUR ROOM (2 BED)	HB 3068	2	2	0	0	0	0
FIRST	LABOUR ROOM (2 BED)	HB 3070	2	2	0	0	0	0
FIRST	NICU 4 BED	HB 3072	4	4	2	0	0	2
FIRST	WARD GYNECOLOGY 6 BED	HB 3077	4	4	0	0	0	0
FIRST	WARD GYNECOLOGY 6 BED	HB 3078	4	4	0	0	0	0

GAS OULETS FOR HOSPITAL, AIIMS PATNA								
LEVEL	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS					BEDHEAD PANEL
			OXYGEN	VACUUM	AIR 4 bar	NITROUS OXIDE	AGSS	
FIRST	WARD GYNECOLOGY 6 BED	HB 3079	4	4	0	0	0	0
FIRST	WARD GYNECOLOGY 6 BED	HB 3088	4	4	0	0	0	0
FIRST	WARD GYNECOLOGY 6 BED	HB 3094	4	4	0	0	0	0
FIRST	WARD ENDOCRINOLOGY 6 BED	HB 3108	4	4	0	0	0	0
FIRST	WARD ENDOCRINOLOGY 6 BED	HB 3114	4	4	0	0	0	0
FIRST	WARD ENDOCRINOLOGY 6 BED	HB 3122	4	4	0	0	0	0
FIRST	WARD ENDOCRINOLOGY 6 BED	HB 3123	4	4	0	0	0	0
FIRST	WARD ENDOCRINOLOGY 6 BED	HB 3124	4	4	0	0	0	0
FIRST	CARDIOTHORACIC WARD 6 BED	HB 3135	4	4	0	0	0	0
FIRST	CARDIOTHORACIC WARD 6 BED	HB 3141	4	4	0	0	0	0
FIRST	CARDIOTHORACIC WARD 6 BED	HB 3150	4	4	0	0	0	0
FIRST	CARDIOTHORACIC WARD 6 BED	HB 3151	4	4	0	0	0	0
FIRST	CARDIOTHORACIC WARD 6 BED	HB 3152	4	4	0	0	0	0
FIRST	CARDIOLOGY WARD 6 BED	HB 3162	4	4	0	0	0	0
FIRST	CARDIOLOGY WARD 6 BED	HB 3168	4	4	0	0	0	0
FIRST	CARDIOLOGY WARD 6 BED	HB 3176	4	4	0	0	0	0
FIRST	CARDIOLOGY WARD 6 BED	HB 3177	4	4	0	0	0	0
FIRST	CARDIOLOGY WARD 6 BED	HB 3178	4	4	0	0	0	0
FIRST	MEDICAL ICU 9 BED	HB 3182	18	18	9	0	0	9
SECOND	WARD GENERAL MEDICINE 6 BED	HB 4004	4	4	0	0	0	0
SECOND	WARD GENERAL MEDICINE 6 BED	HB 4005	4	4	0	0	0	0
SECOND	WARD GENERAL MEDICINE 6 BED	HB 4006	4	4	0	0	0	0
SECOND	WARD GENERAL MEDICINE 6 BED	HB 4012	4	4	0	0	0	0
SECOND	WARD GENERAL MEDICINE 6 BED	HB 4013	4	4	0	0	0	0
SECOND	WARD GENERAL MEDICINE 6 BED	HB 4014	4	4	0	0	0	0
SECOND	WARD GENERAL MEDICINE 6 BED	HB 4023	4	4	0	0	0	0
SECOND	WARD GENERAL MEDICINE 6 BED	HB 4029	4	4	0	0	0	0
SECOND	WARD GENERAL MEDICINE 6 BED	HB 4040	4	4	0	0	0	0
SECOND	WARD GENERAL MEDICINE 6 BED	HB 4046	4	4	0	0	0	0
SECOND	WARD ENT 6 BED	HB 4057	4	4	0	0	0	0
SECOND	WARD ENT 6 BED	HB 4063	4	4	0	0	0	0
SECOND	WARD ENT 6 BED	HB 4072	4	4	0	0	0	0
SECOND	WARD ENT 6 BED	HB 4073	4	4	0	0	0	0
SECOND	WARD ENT 6 BED	HB 4074	4	4	0	0	0	0

GAS OULETS FOR HOSPITAL, AIIMS PATNA								
LEVEL	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS					BEDHEAD PANEL
			OXYGEN	VACUUM	AIR 4 bar	NITROUS OXIDE	AGSS	
SECOND	WARD PAEDEATRICS 6 BED	HB 4086	4	4	0	0	0	0
SECOND	WARD PAEDEATRICS 6 BED	HB 4092	4	4	0	0	0	0
SECOND	WARD PAEDEATRICS 6 BED	HB 4101	4	4	0	0	0	0
SECOND	WARD PAEDEATRICS 6 BED	HB 4102	4	4	0	0	0	0
SECOND	WARD PAEDEATRICS 6 BED	HB 4103	4	4	0	0	0	0
SECOND	WARD PAEDEATRICS 6 BED	HB 4113	4	4	0	0	0	0
SECOND	WARD PAEDEATRICS 6 BED	HB 4119	4	4	0	0	0	0
SECOND	WARD PAEDEATRICS 6 BED	HB 4128	4	4	0	0	0	0
SECOND	WARD PAEDEATRICS 6 BED	HB 4129	4	4	0	0	0	0
SECOND	WARD PAEDEATRICS 6 BED	HB 4130	4	4	0	0	0	0
SECOND	MEDICAL PAEDEATRICS ICU 9 BED	HB 4154	18	18	9	0	0	9
SECOND	PAEDEATRICS SURGERY WARD 6 BED	HB 4157	4	4	0	0	0	0
SECOND	PAEDEATRICS SURGERY WARD 6 BED	HB 4171	4	4	0	0	0	0
SECOND	PAEDEATRICS SURGERY WARD 6 BED	HB 4172	4	4	0	0	0	0
SECOND	EYE WARD 6 BED	HB 4184	4	4	0	0	0	0
SECOND	EYE WARD 6 BED	HB 4190	4	4	0	0	0	0
SECOND	EYE WARD 6 BED	HB 4198	4	4	0	0	0	0
SECOND	EYE WARD 6 BED	HB 4199	4	4	0	0	0	0
SECOND	EYE WARD 6 BED	HB 4200	4	4	0	0	0	0
THIRD	GENERAL SURGERY WARD 6 BED	HB 5004	4	4	0	0	0	0
THIRD	GENERAL SURGERY WARD 6 BED	HB 5005	4	4	0	0	0	0
THIRD	GENERAL SURGERY WARD 6 BED	HB 5006	4	4	0	0	0	0
THIRD	GENERAL SURGERY WARD 6 BED	HB 5012	4	4	0	0	0	0
THIRD	GENERAL SURGERY WARD 6 BED	HB 5013	4	4	0	0	0	0
THIRD	GENERAL SURGERY WARD 6 BED	HB 5014	4	4	0	0	0	0
THIRD	GENERAL SURGERY WARD 6 BED	HB 5021	4	4	0	0	0	0
THIRD	GENERAL SURGERY WARD 6 BED	HB 5027	4	4	0	0	0	0
THIRD	GENERAL SURGERY WARD 6 BED	HB 5038	4	4	0	0	0	0
THIRD	GENERAL SURGERY WARD 6 BED	HB 5043	4	4	0	0	0	0
THIRD	GENERAL SURGERY WARD 6 BED	HB 5055	4	4	0	0	0	0
THIRD	GENERAL SURGERY WARD 6 BED	HB 5061	4	4	0	0	0	0
THIRD	GENERAL SURGERY WARD 6 BED	HB 5072	4	4	0	0	0	0
THIRD	GENERAL SURGERY WARD 6 BED	HB 5078	4	4	0	0	0	0
THIRD	GENERAL SURGERY WARD 6 BED	HB 5087	4	4	0	0	0	0

GAS OULETS FOR HOSPITAL, AIIMS PATNA								
LEVEL	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS					BEDHEAD PANEL
			OXYGEN	VACUUM	AIR 4 bar	NITROUS OXIDE	AGSS	
THIRD	GENERAL SURGERY WARD 6 BED	HB 5088	4	4	0	0	0	0
THIRD	GENERAL SURGERY WARD 6 BED	HB 5089	4	4	0	0	0	0
THIRD	GENERAL SURGERY WARD 6 BED	HB 5094	4	4	0	0	0	0
THIRD	GENERAL SURGERY WARD 6 BED	HB 5095	4	4	0	0	0	0
THIRD	GENERAL SURGERY WARD 6 BED	HB 5096	4	4	0	0	0	0
THIRD	TB & RESPIRATORY DISEASES WARD 6 BED	HB 5107	4	4	0	0	0	0
THIRD	TB & RESPIRATORY DISEASES WARD 6 BED	HB 5113	4	4	0	0	0	0
THIRD	TB & RESPIRATORY DISEASES WARD 6 BED	HB 5122	4	4	0	0	0	0
THIRD	TB & RESPIRATORY DISEASES WARD 6 BED	HB 5123	4	4	0	0	0	0
THIRD	TB & RESPIRATORY DISEASES WARD 6 BED	HB 5124	4	4	0	0	0	0
THIRD	NEPHROLOGY WARD 6 BED	HB 5135	4	4	0	0	0	0
THIRD	NEPHROLOGY WARD 6 BED	HB 5141	4	4	0	0	0	0
THIRD	NEPHROLOGY WARD 6 BED	HB 5150	4	4	0	0	0	0
THIRD	NEPHROLOGY WARD 6 BED	HB 5151	4	4	0	0	0	0
THIRD	NEPHROLOGY WARD 6 BED	HB 5152	4	4	0	0	0	0
THIRD	DIALYSIS UNIT (WARD) 14 BED	HB 5172	28	28	14	0	0	14
THIRD	PSYCHIATRY WARD 6 BED	HB 5175	4	4	0	0	0	0
THIRD	PSYCHIATRY WARD 6 BED	HB 5176	4	4	0	0	0	0
THIRD	PSYCHIATRY WARD 6 BED	HB 5177	4	4	0	0	0	0
THIRD	PSYCHIATRY WARD 6 BED	HB 5186	4	4	0	0	0	0
THIRD	PSYCHIATRY WARD 6 BED	HB 5192	4	4	0	0	0	0
FOURTH	SURGICAL GASTROENDROLOGY WARD 6 BED	HB 6003	4	4	0	0	0	0
FOURTH	SURGICAL GASTROENDROLOGY WARD 6 BED	HB 6004	4	4	0	0	0	0
FOURTH	SURGICAL GASTROENDROLOGY WARD 6 BED	HB 6005	4	4	0	0	0	0
FOURTH	SURGICAL GASTROENDROLOGY WARD 6 BED	HB 6013	4	4	0	0	0	0
FOURTH	SURGICAL GASTROENDROLOGY WARD 6 BED	HB 6019	4	4	0	0	0	0
FOURTH	GASTROENDROLOGY WARD 6 BED	HB 6026	4	4	0	0	0	0
FOURTH	GASTROENDROLOGY WARD 6 BED	HB 6027	4	4	0	0	0	0
FOURTH	GASTROENDROLOGY WARD 6 BED	HB 6028	4	4	0	0	0	0
FOURTH	GASTROENDROLOGY WARD 6 BED	HB 6036	4	4	0	0	0	0
FOURTH	GASTROENDROLOGY WARD 6 BED	HB 6042	4	4	0	0	0	0
FOURTH	DERMATOLOGY WARD 6 BED	HB 6055	4	4	0	0	0	0
FOURTH	DERMATOLOGY WARD 6 BED	HB 6061	4	4	0	0	0	0
FOURTH	DERMATOLOGY WARD 6 BED	HB 6068	4	4	0	0	0	0

GAS OULETS FOR HOSPITAL, AIIMS PATNA								
LEVEL	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS					BEDHEAD PANEL
			OXYGEN	VACUUM	AIR 4 bar	NITROUS OXIDE	AGSS	
FOURTH	DERMATOLOGY WARD 6 BED	HB 6069	4	4	0	0	0	0
FOURTH	DERMATOLOGY WARD 6 BED	HB 6070	4	4	0	0	0	0
FOURTH	CLINICAL HAEMATOLOGY WARD 6 BED	HB 6060	4	4	0	0	0	0
FOURTH	CLINICAL HAEMATOLOGY WARD 6 BED	HB 6066	4	4	0	0	0	0
FOURTH	CLINICAL HAEMATOLOGY WARD 6 BED	HB 6075	4	4	0	0	0	0
FOURTH	CLINICAL HAEMATOLOGY WARD 6 BED	HB 6076	4	4	0	0	0	0
FOURTH	CLINICAL HAEMATOLOGY WARD 6 BED	HB 6076	4	4	0	0	0	0
FIFTH	POST OPERATIVE HOLDING AREA 8 BED	HB 7041	16	16	8	0	0	8
FIFTH	PRE OPERATIVE WARD 6 BED	HB 7070	4	4	0	0	0	0
FIFTH	NEUROLOGY WARD 6 BED	HB 7080	4	4	0	0	0	0
FIFTH	NEUROLOGY WARD 6 BED	HB 7086	4	4	0	0	0	0
FIFTH	NEUROLOGY WARD 6 BED	HB 7095	4	4	0	0	0	0
FIFTH	NEUROLOGY WARD 6 BED	HB 7096	4	4	0	0	0	0
FIFTH	NEUROLOGY WARD 6 BED	HB 7097	4	4	0	0	0	0
FIFTH	BURNS AND PLASTIC SURGERY WARD 6 B	HB 7106	4	4	0	0	0	0
FIFTH	BURNS AND PLASTIC SURGERY WARD 6 B	HB 7112	4	4	0	0	0	0
FIFTH	BURNS AND PLASTIC SURGERY WARD 6 B	HB 7121	4	4	0	0	0	0
FIFTH	BURNS AND PLASTIC SURGERY WARD 6 B	HB 7122	4	4	0	0	0	0
FIFTH	BURNS AND PLASTIC SURGERY WARD 6 B	HB 7123	4	4	0	0	0	0
FIFTH	UROLOGY WARD 6 BED	HB 7131	4	4	0	0	0	0
FIFTH	UROLOGY WARD 6 BED	HB 7137	4	4	0	0	0	0
FIFTH	UROLOGY WARD 6 BED	HB 7145	4	4	0	0	0	0
FIFTH	UROLOGY WARD 6 BED	HB 7146	4	4	0	0	0	0
FIFTH	UROLOGY WARD 6 BED	HB 7147	4	4	0	0	0	0
FIFTH	NEURO SURGERY WARD 6 BED	HB 7153	4	4	0	0	0	0
FIFTH	NEURO SURGERY WARD 6 BED	HB 7159	4	4	0	0	0	0
FIFTH	NEURO SURGERY WARD 6 BED	HB 7167	4	4	0	0	0	0
FIFTH	NEURO SURGERY WARD 6 BED	HB 7168	4	4	0	0	0	0
FIFTH	NEURO SURGERY WARD 6 BED	HB 7169	4	4	0	0	0	0
FIFTH	PRE OPERATIVE WARD 6 BED	HB 7197	4	4	0	0	0	0
FIFTH	POST OPERATIVE HOLDING AREA 8 BED	HB 7202	16	16	8	0	0	8
SIXTH	POST OPERATIVE HOLDING AREA 6 BED	HB 8040	12	12	6	0	0	6
SIXTH	POST OPERATIVE AREA/NURSE STN. 6 BE	HB 8045	12	12	6	0	0	6
SIXTH	POST OPERATIVE HDU/NURSE STN.6 BED	HB 8046	12	12	6	0	0	6

GAS OULETS FOR HOSPITAL, AIIMS PATNA								
LEVEL	DESCRIPTION OF ROOM	ROOM NO	NO OF OULETS					BEDHEAD PANEL
			OXYGEN	VACUUM	AIR 4 bar	NITROUS OXIDE	AGSS	
SIXTH	PRE OPERATIVE WARD/NURSE STATION 8 BED	HB 8072	6	6	0	0	0	0
SIXTH	CATHLAB	HB 8095	2	2	2	0	0	0
SIXTH	CATHLAB	HB 8098	2	2	2	0	0	0
SIXTH	CCU WITH NURSE STATION 8 BED	HB 8099	16	16	8	0	0	8
SIXTH	SURGICAL MEDICAL ICU 10 BED	HB 8105	20	20	10	0	0	10
SIXTH	PRIVATE ROOM	HB 8126	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8128	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8130	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8132	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8139	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8141	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8143	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8145	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8155	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8157	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8159	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8161	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8163	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8165	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8175	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8177	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8179	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8181	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8188	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8190	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8192	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8194	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8196	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8198	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8200	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8202	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8209	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8211	1	1	0	0	0	0

GAS OULETS FOR HOSPITAL, AIIMS PATNA								
LEVEL	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS					BEDHEAD PANEL
			OXYGEN	VACUUM	AIR 4 bar	NITROUS OXIDE	AGSS	
SIXTH	PRIVATE ROOM	HB 8213	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8215	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8223	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8225	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8227	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8229	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8231	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8233	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8235	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8241	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8243	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8245	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8247	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8249	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8251	1	1	0	0	0	0
SIXTH	PRIVATE ROOM	HB 8253	1	1	0	0	0	0
	TOTAL		931	931	101	0	0	94

GAS OULETS FOR TRAUMA, AIIMS PATNA								
LEVEL	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS					BEDHEAD PANEL
			OXYGEN	VACUUM	AIR 4 bar	NITROUS OXIDE	AGSS	
GROUND	TRIAGE 8 BED	TB1007	6	6	0	0	0	0
GROUND	OBSERVATION WARD 8 BED	TB1010	6	6	0	0	0	0
GROUND	RESUSCITATION	TB1008	12	12	6	0	0	6
FIRST	ICU 20 BED	TB2001	40	40	20	0	0	20
SECOND	BED ICU 18 BED	TB 3002	36	36	18	0	0	18
THIRD	POST OPERATIVE WARD-5 BED	TB 4009	10	10	5	0	0	5
THIRD	PRE OPERATIVE WARD-4 BED	TB 4029	4	4	0	0	0	0
FOURTH	POST OPERATIVE WARD-5 BED	TB 5003	10	10	5	0	0	5
FOURTH	BURN ICU 8 BED	TB 5025	16	16	8	0	0	8
	TOTAL		140	140	62	0	0	62

GAS OULETS FOR OPD, AIIMS PATNA										
LEVEL	DESCRIPTION OF ROOM	ROOM NO	NO OF OUTLETS						SINGLE ARM MOVABLE PENDANT	BEDHEAD PANEL
			OXYGEN	VACUUM	AIR 4 bar	AIR 7 bar	NITROUS OXIDE	AGSS		
LOWER GROUND	CHEMOTHERAPY TREATMENT ROOM(2 BED)	OB1026- OB1027	2	2	0	0	0	0	0	0
LOWER GROUND	LINEAR ACCELERATOR	OB1031	1	1	1	0	0	0	0	0
LOWER GROUND	LINEAR ACCELERATOR	OB1032	1	1	1	0	0	0	0	0
GROUND	OPHTHALMOLOGY MINOR OT	OB 2003	2	2	2	0	1	1	1	0
GROUND	GENERAL SURGERY MINOR OT	OB 2083	2	2	2	0	1	1	1	0
SECOND	PAEDIATRIC SURGERY MINOR OT	OB4007	2	2	2	0	1	1	1	0
SECOND	ENT MINOR OT	OB4044	2	2	2	0	1	1	1	0
SECOND	OBSTETRICS AND GYNAECOLOGY MINOR OT	OB4064	2	2	2	0	1	1	1	0
FIFTH	BURNS AND PLASTIC MINOR OT	OPD 7036	2	2	2	0	1	1	1	0
	TOTAL		16	16	14	0	6	6	6	0

	NO OF OUTLETS						SINGLE ARM MOVABLE PENDANT	DOUBLE ARM MOVABLE PENDANT	SURGEONS PENDANT	BEDHEAD PANEL
	OXYGEN	VACUUM	AIR 4 bar	AIR 7 bar	NITROUS OXIDE	AGSS				
HOSPITAL	931	931	101	0	0	0	0	0	0	94
TRAUMA	140	140	62	0	0	0	0	0	0	62
OPD	16	16	14	0	6	6	6	0	0	0
TOTAL	1087	1087	177	0	6	6	6	0	0	156